

INSPECTION HISTORY

ROF2017-00930, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDRELAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	06/08/2017	06/09/2017	06/09/2017	Cancel	missing membrane in the roof cement on short sections of wall flashing at both entrys , its marked , OK TO LOAD ROOF !	Morgan L Highfill / 239-849-3389
501 Roof Dry In	06/14/2017	06/15/2017	06/15/2017	Already Done	[2397341674]	Morgan L Highfill / 239-849-3389
502 Roof In Process	06/20/2017	06/21/2017	06/21/2017	Already Done	D/V ok	Dempsey H Vick / 239-850-2731
503 Final Roof	07/10/2017	07/11/2017	07/11/2017	Already Done	[2399101669]	Morgan L Highfill / 239-849-3389