

INSPECTION HISTORY

ROF2017-00926, Roof, TEAR OFF EXISTING TILE AND INSTALL NEW UNDERLAYMENT AND NEW TILE

| INSPECTION TYPE     | REQUESTED DATE | SCHEDULED DATE | INSPECTED DATE | STATUS       | COMMENTS  | INSPECTOR NAME/PHONE             |
|---------------------|----------------|----------------|----------------|--------------|---|----------------------------------|
| 501 Roof Dry In     | 06/02/2017     | 06/05/2017     | 06/05/2017     | Already Done |   | Morgan L Highfill / 239-849-3389 |
| 502 Roof In Process | 06/14/2017     | 06/15/2017     | 06/15/2017     | Already Done | [2397341674]d/v,s ok  | Morgan L Highfill / 239-849-3389 |
| 503 Final Roof      | 07/10/2017     | 07/11/2017     | 07/11/2017     | Fail         | [2399101669] on left unit crooked , high tile at solar tube / 2 broken tile | Morgan L Highfill / 239-849-3389 |
| 503 Final Roof      | 07/24/2017     | 07/25/2017     | 07/25/2017     | Already Done | [2399101669]  | Dempsey H Vick / 239-850-2731    |