

INSPECTION HISTORY

ROF2017-00923, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	09/20/2017	09/21/2017	09/21/2017	Cancel		Dempsey H Vick / 239-850-2731
501 Roof Dry In	09/25/2017	09/26/2017	09/26/2017	Already Done		Dempsey H Vick / 239-850-2731
502 Roof In Process	10/13/2017	10/16/2017	10/16/2017	Already Done	[2398989740]	Morgan L Highfill / 239-849-3389
503 Final Roof	11/03/2017	11/06/2017	11/07/2017	Fail	[2398989740] Missing tile. tool left on roof. clean gutters from debri and reattach gutter spikes.	Dempsey H Vick / 239-850-2731
503 Final Roof	12/07/2017	12/08/2017	12/13/2017	Fail	[2398989740] Loose tile @ bottom of valley.	Dempsey H Vick / 239-850-2731
503 Final Roof	01/19/2018	01/22/2018	01/22/2018	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731