

INSPECTION HISTORY

ROF2017-00931, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	06/26/2017	06/27/2017	06/27/2017	Already Done	no r/b,s	Morgan L Highfill / 239-849-3389
502 Roof In Process	06/30/2017	07/03/2017	07/03/2017	Already Done	[2397341674]d/v,s ok	Morgan L Highfill / 239-849-3389
502 Roof In Process	07/03/2017	07/05/2017	07/05/2017	Already Done	[2399101669]	Morgan L Highfill / 239-849-3389
503 Final Roof	08/09/2017	08/10/2017	08/10/2017	Fail	[2399101669] loose tile at off ridge vents , not useing enough foam to secure tile at 2 off ridge vents on back / 1 cracked tile on back	Morgan L Highfill / 239-849-3389
503 Final Roof	02/26/2018	02/27/2018	03/02/2018	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731