

INSPECTION HISTORY

ROF2017-00947, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	08/03/2017	08/04/2017	08/04/2017	Already Done	[2399101669]	Barry L Albritton / 239-850-4002
502 Roof In Process	09/01/2017	09/05/2017	09/05/2017	Already Done		Morgan L Highfill / 239-849-3389
503 Final Roof	11/01/2017	11/02/2017	11/03/2017	Fail	[2398989740] 5 broken tile at front valley , 1 on rt side all on rt unit	Morgan L Highfill / 239-849-3389
503 Final Roof	12/07/2017	12/08/2017	12/15/2017	Already Done	[2398989740]	Morgan L Highfill / 239-849-3389
Other Roof	08/14/2017			Pending	needs 503 final roof inspection	/
Other Roof	08/14/2017			Pending	needs 503 final roof inspection	/
Other Roof	08/14/2017			Pending	needs 503 final roof inspection	/
Other Roof	08/14/2017			Pending	needs 503 final roof inspection	/