

INSPECTION HISTORY

ROF2017-00936, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	07/14/2017	07/17/2017	07/17/2017	Cancel	[2399101669]will need a letter from tu plus addressing short selvedge at horizontal laps	Morgan L Highfill / 239-849-3389
501 Roof Dry In	08/02/2017	08/03/2017	08/03/2017	Cancel	[2399101669] Need engineers letter to address short salvage edge at horizontal laps.	Barry L Albritton / 239-850-4002
502 Roof In Process	08/02/2017	08/03/2017	08/03/2017	Already Done	[2399101669]	Barry L Albritton / 239-850-4002
503 Final Roof	11/01/2017	11/02/2017	11/03/2017	Already Done	[2398989740]	Morgan L Highfill / 239-849-3389