

INSPECTION HISTORY

ROF2017-00937, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	07/27/2017	07/28/2017	07/28/2017	Already Done	[2399101669] H+R and d/v ok	Dempsey H Vick / 239-850-2731
502 Roof In Process	08/03/2017	08/04/2017	08/04/2017	Already Done	[2399101669]	Barry L Albritton / 239-850-4002
503 Final Roof	09/25/2017	09/26/2017	09/26/2017	Fail	Clean tile debri from gutters and add straps as/needed. Loose tiles at ORV.	Dempsey H Vick / 239-850-2731
503 Final Roof	11/01/2017	11/02/2017	11/03/2017	Cancel	[2398989740] tile blow loose at off ridge vents	Morgan L Highfill / 239-849-3389
503 Final Roof	12/07/2017	12/08/2017	12/13/2017	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731
503 Final Roof	12/12/2017	12/13/2017	12/13/2017	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731