

INSPECTION HISTORY

ROF2017-00939, Roof, TEAR OFF EXISTING TILE ROOF AND INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	05/30/2017	05/31/2017	05/31/2017	Already Done		Barry L Albritton / 239-850-4002
501 Roof Dry In	06/21/2017	06/22/2017	06/21/2017	Cancel	[2397341674]	/
501 Roof Dry In	06/21/2017	06/22/2017	06/21/2017	Cancel	[2397341674]	/
501 Roof Dry In	06/21/2017	06/22/2017	06/21/2017	Cancel	[2397341674]	/
501 Roof Dry In	06/21/2017	06/22/2017	06/21/2017	Cancel	[2397341674]	/
502 Roof In Process	06/12/2017	06/13/2017	06/13/2017	Already Done	H+R,D/V's ok	Dempsey H Vick / 239-850-2731
503 Final Roof	08/07/2017	08/08/2017	08/08/2017	Fail	[2399101669]approx 8/9 broken tile , 2 on back most on front , double check ALL / loose tile around solar tube , rt unit	Morgan L Highfill / 239-849-3389
503 Final Roof	09/05/2017	09/07/2017	09/18/2017	Cancel	[2399101669]still have 3 broken tile , 2 on back , left unit and 1 on rt unit at dormer valley ,	Morgan L Highfill / 239-849-3389
503 Final Roof	01/19/2018	01/22/2018	01/25/2018	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731