

INSPECTION HISTORY

ROF2017-00904, Roof, TEAR OFF EXISTING TILE INSTALL NEW UNDERLAYMENT AND TILE

INSPECTION TYPE	REQUESTED DATE	SCHEDULED DATE	INSPECTED DATE	STATUS	COMMENTS	INSPECTOR NAME/PHONE
501 Roof Dry In	07/05/2017	07/06/2017	07/06/2017	Already Done	[2399101669]	Morgan L Highfill / 239-849-3389
501 Roof Dry In	07/10/2017	07/11/2017	07/11/2017	Already Done	[2399101669] 501 done 7/6/17	Morgan L Highfill / 239-849-3389
502 Roof In Process	07/14/2017	07/17/2017	07/17/2017	Already Done	[2399101669]	Morgan L Highfill / 239-849-3389
503 Final Roof	09/20/2017	09/21/2017	09/21/2017	Cancel	[2399101669] Missing Tile due to high winds	Dempsey H Vick / 239-850-2731
503 Final Roof	12/07/2017	12/08/2017	12/13/2017	Fail	[2398989740] Exposed TU pluss @ bottom of valley, Unit # 8484	Dempsey H Vick / 239-850-2731
503 Final Roof	12/12/2017	12/13/2017	12/13/2017	Cancel	[2398989740]	Dempsey H Vick / 239-850-2731
503 Final Roof	02/07/2018	02/08/2018	02/14/2018	Already Done	[2398989740]	Dempsey H Vick / 239-850-2731